

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 3505-0713:0109 Page 1 of 1

CATEGORY: 3505 -- SERVICE COUNTER DOOR (FIRE-RATED)

LISTEE: COOKSON24 Elmwood Avenue, Crestwood Industrial Park, Mountain Top, PA 18707
Contact: Nathan Mikleton (570) 550-7156
Email: nathan.mikleton@cornellcookson.com

DESIGN: Mineral core countertop with plastic laminated surface. Core consists of two layers of 3/4" vermiculite boards. Plastic laminate max. 0.05". Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 1-1/2 hr.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, fire rating and UL label.

APPROVAL: Listed as a fire rated countertop for use with rolling steel type and service counter type fire doors rated up to 1-1/2 hrs. Refer to listee's Installation Instructions Manual for details.

XLf: 3505-0550:0108

08-03-15 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division