



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	3515-0713:0500
PARENT LISTING No.:	3515-0550:0103
CATEGORY:	3515 - ROLLING STEEL DOOR (FIRE-RATED)
LISTEE:	COOKSON 24 Elmwood Avenue, Mountain Top, PA, 18707 Contact: Mikleton, Nathan (570) 550-7156 Email: nathan.mikleton@cornellcookson.com
DESIGN:	Cookson models ERD10, ERD 11, ERD 20, ERD 21, ERC 10, ERC 11, ERC 20, ERC 21 galvanized or stainless steel rolling fire door. These doors are intended for the protection of openings in interior walls. They are designed for mounting either on the face of the wall or between the jambs under the lintel, bolted to masonry walls and bolted or welded to structural steel construction. The curtain may be operated by handles mounted on the bottom bar, by chain, by hand crank, or by UL listed motor drive assemblies. The doors shall close automatically by the operation of an automatic release mechanism, which incorporates fusible links. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	Fire Rating: 4-hour 3-hour 1-hour 3/4-hour
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, classification and UL label.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

APPROVAL:	<p>Listed as 4-hour, 3-hour, 1--hour or 3/4-hour fire-rated rolling steel doors for use in masonry wall or steel construction. Rolling steel fire doors maximum size of openings:</p> <p align="center">Not exceeding 12' H x 13'6" W Maximum 162 sq. ft.</p> <p>Doors exceeding the above limits are considered oversize doors and are NOT cover under this listing. The design of these doors is based upon, and is similar to, the approval product design but they have not been subject to approval testing due to test facility limitations. Acceptance of these doors is the prerogative of the authority having jurisdiction.</p>
NOTES:	

12-2-2016 dc



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/07/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong** , Program Coordinator
Fire Engineering & Investigations Division